


				24-100589	24-100590	24-100591	24-100592
			가	-	-	-	-
				2024-02-05	2024-02-05	2024-02-05	2024-02-05
1		CFU /mL	100CFU	0	0	0	0
2		/100 mL					
3		/100 mL					
4		mg /L	0.5				
5		mg /L	0.1	0.022	0.016	0.025	0.021
6		mg /L	4.0	0.46	0.83	0.43	0.58

.61949 78 4 / (062) 370-1308 / (062) 370-1391

				24-100589	24-100590	24-100591	24-100592
			가	-	-	-	-
				2024-02-05	2024-02-05	2024-02-05	2024-02-05
7	(Cu)	mg /L	1				
8	(pH)	-	5.8-8.5	6.5	7.5	6.7	7.1
9		mg /L	3				
10		mg /L	0.3				
11		NTU	0.5	0.10	0.15	0.13	0.09

				24-100593	24-100594	24-100595	24-100596
			가	-	-	-	-
				2024-02-05	2024-02-05	2024-02-05	2024-02-05
1		CFU /mL	100CFU	0	0	0	0
2		/100 mL					
3		/100 mL					
4		mg /L	0.5				
5		mg /L	0.1	0.026	0.013	0.026	0.037
6		mg /L	4.0	0.85	0.73	0.42	0.51
7	(Cu)	mg /L	1				
8	(pH)	-	5.8-8.5	6.7	7.4	6.8	6.8
9		mg /L	3		0.007	0.002	
10		mg /L	0.3				
11		NTU	0.5	0.14	0.18	0.11	0.15

 <div> <div>한국수자원공사</div> <div>Korea Water Resources Corporation</div> </div>					
				24-100589	7
					3/3
.61949	78	4 /	(062) 370-1308 /	(062) 370-1391	

2024 02 28

■

